


Fuel Load Less than 1m³ - Fuel Loss Contained in Sump. Sump to be emptied by specialist Contractor. Channel drain and Liquid Storage Tank to be checked for any fuel and cleaned by specialist Contractor if required.



Rev 1 - 11/01/22 Title amended
 Rev 0 - 12/10/21 First Issue

fraser ARCHITECTURE



Fraser Architecture LLP
 An Taigh Dearg
 21a Carinish
 Isle of North Uist, HS6 5EJ
 T. 01876 580 315

Title: Pad Containment - Indicative - 3 of 7
 Project: Infrastructure Works for Launching Sounding Rockets
 Client: Comhairle nan Eilean Siar
 Job No: 19_10

Dwg No: (00)30
 Revision: 1
 Date: 12/10/21
 Scale: 1:250 (A4)