



**From:** Alasdair Maclean  
**Sent:** 29 April 2024 14:27  
**To:** Planning Consultations - Stornoway  
**Subject:** RE: 24/00155/PPDM - Major application for Battery Storage at Newton Street, Stornoway, Isle of Lewis

A building warrant is required for the fence and acoustic barrier as they are both more than 2m in height.

Alasdair MacGilleEathain (Alasdair Maclean) | Oifigear Inbhean Thogalaichean (Building Standards Officer) | Comhairle nan Eilean Siar | Rathad Shanndabhaig (Sandwick Road) | Steòrnabhagh (Stornoway) | Eilean Leòdhais (Isle of Lewis) | HS1 2BW | [alasdair.maclean@cne-siar.gov.uk](mailto:alasdair.maclean@cne-siar.gov.uk)

Note: The website, telephony system and many ICT systems of Comhairle nan Eilean Siar were subject to a cyber-attack on 7 November 2023. This is the subject of an ongoing criminal investigation and has had some impact on the delivery of Services. Please refer to our temporary website - <https://www.cne-siar.gov.uk/>

**Building Standards Telephone No: 01851 822692**

Your views are important to us, please take a moment to share your experience in the - [National Customer Satisfaction Survey](#)

---

Ag Obair Comhla airson na h-Eileanan Siar **COMHAIRLE NAN EILEAN SIAR** Working Together for the Western Isles

 Beachdaich air glèidhteachas mus cleachd thu pàipear airson seo (Help save paper - do you need to print this e-mail?)

---

**From:** Planning Consultations - Stornoway <[planningconsultations-sty@cne-siar.gov.uk](mailto:planningconsultations-sty@cne-siar.gov.uk)>  
**Sent:** Monday, April 29, 2024 11:29 AM  
**Subject:** 24/00155/PPDM - Major application for Battery Storage at Newton Street, Stornoway, Isle of Lewis

Good morning,

## **PLANNING APPLICATION CONSULTATION**

[24/00155/PPDM- Battery Storage at Newton Street, Stornoway, Isle of Lewis](#)

Date of Consultation: **19 April 2024**

Date by which response required: **17 May 2024**

Governing Legislation: Town and Country Planning (Scotland) Act 1997

Consultation Type: Planning Permission Detailed Major

[Application can be viewed here.](#)

### **Reason for Consultation**

Roads – Access from adjacent roadway to new hardstanding

Building Standards (Ali Maclean) – Hardstanding over 50sqm and site office building